NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0925

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of March 9th, 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

Addresable single output module
SensoIRIS MiniOUT, Belinda MiniOUT, Erida MiniOUT, Marl MiniOUT, Smoke sense MiniOUT, Expera MiniOUT

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

Teletek Electronics JSC,
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

and produced in the manufacturing plant

Teletek Electronics JSC,
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-18:2005, EN 54-18:2005/AC:2007

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on December 6th, 2024 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

EVPÚ, a.s. NOVÁ DUBNICA Notified Body No. 1293

Nová Dubnica, December 6th, 2024

Michal M i š i a k
Head of CB NB No. 1293

056195

© Tlačiareň cenín KASICO, a. s., Bratislava, KC24-00065

Annex to Certificate No. 1293 - CPR - 0925 from December 6th, 2024

General information

SensoIRIS MiniOUT (and derived variants) is a compact addressable module with one unmonitored output. The module is designed for built-in installation in the mounting box of the device (PCB only); or it can be situated into small plastic box for wall mounting. The module is powered on from the fire panel and can be controlled via TTE communication protocol. The unmonitored relay output is suitable to control of 24V AC voltage circuits. The output terminals are wired with color cables for easy recognition during the module's installation.

Technical specifications

Operating voltage	15 ÷ 32V DC
Relay ratings	0.25A/24V AC; 2A/30V DC
Relay rated current	2A
Relay max. switching current	5A
Relay switching power	60W, 62.5VA
Mounting	Indoor use

Essential characteristics	**Harmonised technical specification** **EN 54-18: 2005, EN 54-18: 2005/AC: 2007**	**Performance**
Response delay (response time)	cl. 5.2	Pass
Performance under fire conditions	cl. 5.1.4	Pass
Operational reliability	cl. 5.1.4	Pass
Durability of operational reliability and response delay: temperature resistance	cl. 5.3, 5.4	Pass
Durability of operational reliability: vibration resistance	cl. 5.8 to 5.11	Pass
Durability of operational reliability: humidity resistance	cl. 5.5, 5.6	Pass
Durability of operational reliability: corrosion resistance	cl. 5.7	Pass
Durability of operational reliability: electrical stability	cl. 5.2, 5.12	Pass

EVPÚ, a.s. NOVÁ DUBNICA Notified Body No 1293

Nová Dubnica, December 6th, 2024

Michal M i š i a k
Head of CB NB No. 1293